

Requirement	Construction Contractor Daily Use Checklist for EXCAVATION	YES	NO	NA
	Has an excavation permit been obtained from the facilities Office and utility lines identified?			
1926.651	Are ladders or ramps provided for employee egress in trenches 4 feet or more in depth and located so that no more than 25 feet of lateral travel is required to reach the means of egress?			
1926.652	Is trenching excavations over 5 feet in depth shored, braced or sloped to protect employees from cave-ins?			
1926.651	Is shored excavation or other materials located or retained 2 feet from the edge of the excavation to keep employees protected from loose material that could fall into the trench?			
1926.651	Are walkways provided when employees or equipment are required to cross over excavations?			
1926.651	Are walkways that are six feet or more above lower levels of excavations equipped with guardrails?			
1926.28	Are employees provided with and are they required to wear proper safety equipment?			
1926.651	If a hazardous atmosphere is identified, is ventilation provided or is respiratory protection in use?			
1926.651	Have hazardous objects been removed from the excavation area or blocked securely?			
1926.652	Are damaged materials or equipment removed from service?			
1926.501 1926.651	Is the excavation barricaded and posted with warning signs for the safety of personnel?			
MPG 8500.1	Is the operation in compliance with the Environmental Management Program (including Stormwater Pollution Prevention Plan)			
Supervisor Signature: _____ PO#/FWR# _____ Date: _____ Company: _____ Comments: _____				